

# **NOTICE**

## **CARBON MONOXIDE ALARMS REQUIRED FOR DWELLINGS THAT USE FOSSIL FUELS**

### **REQUIRED FOR DWELLINGS CONSTRUCTED UNDER PERMITS ISSUED ON AND AFTER 01/01/2008**

[House Bill 401](#), passed by the Md. General Assembly requires the installation of a carbon monoxide alarm in a central location outside of each sleeping area or, under specified circumstances, within 25 feet of any carbon monoxide-producing fixture and equipment within a dwelling; prohibits a person from rendering a carbon monoxide alarm inoperable with a specified exception; requires that a specified disclosure form include specified information about a carbon monoxide alarm under specified circumstances; etc.

Reference: Subtitle 11. Carbon Monoxide Alarms, Public Safety Article, Annotated Code of Maryland